



Ref. Certif. No.

SG ITS-4727M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product
Produit

Mono Crystalline Silicon Terrestrial Photovoltaic Module

Name and address of the applicant
Nom et adresse du demandeurAU Optronics Corporation
No.1, Li-Hsin Road 2, Hsinchu Science Park, Hsinchu 30078, Taiwan,
R.O.CName and address of the manufacturer
Nom et adresse du fabricantAU Optronics Corporation
No.1, Li-Hsin Road 2, Hsinchu Science Park, Hsinchu 30078, Taiwan,
R.O.C.Name and address of the factory
Nom et adresse de l'usineAU Optronics Corporation
No.1, Jhongke Rd, Central Taiwan Science Park Taichung 40763, Taiwan,
R.O.CNote: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page Additional Information on page 2Ratings and principal characteristics
Valeurs nominales et caractéristiques principalesSystem voltage 1000V, Class of application A, Class II, Fire resistance
Class C, Maximum over-current protection rating 15ATrademark (if any)
Marque de fabrique (si elle existe)

BenQ Solar (LOGO)

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

-

Model / Type Ref.
Ref. De typePM318Bxx_xxx , PM096Bxx_xxx
(1st and 2nd "x" can be 0-9, a-z, A-Z or blank for marketing purpose.
3rd-5th "x" can be 298, 300, 303, 305, 308, 310, 313, 315, 318, 320, 323,
325, 327, 330, 333 and 335)Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire,, peuvent
être indiqués sur la 2^{ème} page Additional Information on page 2A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 61215: 2005
IEC 61730-1: 2004
IEC 61730-2: 2004As shown in the Test Report Ref. No. which forms part of
this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce CertificatSH11090765-001, SH11090765-002, SH11090765-003,
SH11090765-001m1a1, SH11090765-002m1a1, SH11090765-003m1a1,
SH11090765-001m2a1, SH11090765-002m2a1, SH11090765-003m2a1This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de CertificationIntertek Testing Services (Singapore) Pte Ltd
5, Pereira Road, #06-01
Asiawide Industrial Building
Singapore 368025

Date: 13 June 2013

Signature:

Christopher Hee